



## Product certificate K14032/04

Issued 2023-02-01

Replaces K14032/03

Page 1 of 2

### Vapour recovery coupler for tank installations

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### MADIC industries

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K917/02 "Vapour recovery coupler for tank installations" dated 2010-05-07 inclusive amendment sheet dated 2015-09-01.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

# CERTIFICATE

28/17/015

**Kiwa Nederland B.V.**  
Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
NL.Kiwa.info@Kiwa.com  
[www.kiwa.nl](http://www.kiwa.nl)

**Supplier**  
MADIC industries  
1155 Avenue Jean-Baptiste Godin  
33240 SAINT-ANDRÉ-DE-CUBZAC  
France  
Tel. +33 5 57 80 80 80  
contact.industries@madic.com  
www.groupe.madic.com

**Representative**  
Lutters Handel B.V.  
Mercuriusweg 13  
6971 GW BRUMMEN (Gld.)  
Nederland  
Tel. +31(0)57 55 62 545  
lutters@luttershandel.nl  
www.luttershandel.nl



**Certification process  
consists of initial and  
regular assessment of:**

- quality system
- product

## Vapour recovery coupler for tank installations

---

### Technical specification

Vapour recovery coupler, type and specifications

Type	diameter	mm	
	100 mm	DN 100	Camlock
	80 mm	DN 80	Camlock
	80 mm	DN 100	Camlock

### Application and use

The vapour recovery couplers are intended to be applied in storage installations for liquid petroleum products, where the vapour of liquid petroleum is returned from the storage installation to the road tank vehicle (stage 1).

The tank installations are intended for the storage of liquid petroleum products in underground storage installations under atmospheric pressure and ambient temperature.

### Marking

The products are marked with the Kiwa-mark.

Place of the mark: on body of vapour recovery coupler.

Compulsory specifications:

- manufacturer's name or mark;
- type and diameter identification;
- factory production number and identification number / date of production;
- Kiwa-mark.

Method of marking:

- non-erasable;
- clearly visible.

### Recommendations for customers

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- MADIC industries

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.